


HOW DO WE  
MAKE  
ENERGY?

- 1** SOLAR PANELS ON THE MEDIA CENTER ROOF TURN SUNLIGHT INTO ELECTRICITY. THEY ARE MADE UP OF MANY SOLAR CELLS WITH EACH CELL MADE UP OF TWO DIFFERENT LAYERS STUCK TOGETHER.
- 2** THE TOP LAYER IS LOADED WITH ELECTRONS AND WHEN SUNLIGHT STRIKES THE SURFACE, THE ELECTRONS BEGIN TO JUMP TO THE SECOND LAYER CAUSING A FLOW OF ELECTRONS
- 3** THAT FLOW OF ELECTRONS CAUSED BY THE SUNLIGHT CREATES ELECTRICITY WHICH CAN BE USED TO POWER LIGHTS AND OTHER ELECTRICAL DEVICES THROUGHOUT THE SCHOOL.



# Beyond Zero Net Energy Buildings Case Studies

SF Symposium on ZNE Buildings and Beyond:  
Balancing Building and Grid Objectives


---

October 25, 2017  
Paul Schwer, PE  
President

# Learning Objectives



---

1. Beyond Zero Net Energy Case Studies
2. MEETS - Metered Energy Efficiency Transaction Structure
3. Thermal Comfort path to Zero Net Energy
4. The path to a DC powered building







# Rise of Renewables - States




New York  
50% renewable  
power by 2030




# Cities with Renewable Pledges in 2016

---



# Cities with Renewable Pledges in 2017

As of June 22<sup>nd</sup> 2017, 36 US cities have committed to 100% renewables



# Net Zero Energy: PAE Projects





# The Bullitt Center

Seattle, WA




Architect: The Miller Hull Partnership









# Net Zero Energy in Seattle



# Bullitt Center


## HVAC System Overview




# Bullitt Center Performance

Actual EUI ~ 12 kBTU/SF/yr, lower than Modeled EUI of ~ 16

ACTUAL




MODELED



# Reduction Plug Loads

---

2007






# Reduction Plug Loads

---

2017




Total: **45 Watts**

# Plug Loads

---

Progression of PAE Computer Energy use



# “Negawatts”

---




# MEETS Concept

---

## Metered Energy Efficiency Transaction Structure


1. Tenants pay for Baseline
2. Measure the saved energy with a meter
3. Buy and sell it through PPA *just like generation*



**DeltaMeter®**


# Predicted vs. Actual

## Bullitt Center Performance




# Predicted vs. Actual

## Bullitt Center Performance



# Predicted vs. Actual


## Bullitt Center Performance



# Results

## NPV of Projected 20-year MEETS Cash Flow

Based on first-year, 4.4 % electric rate escalation, 3% discount rate





# MEETS Benefits

---



## Owner

New \$ flow

Receive ECM savings

Tenants pay normal rates



## Investor

~30 yr return

Increased \$ for performance

Like a PPA



## Utility

~30 yr fixed revenue

Helps meet regulatory requirements

# Financial Considerations

---

## Direct Construction Costs

**\$350 / SF**

Includes City infrastructure improvements and costs associated with the PV array.

**\$265 / SF**

Does not include PV, water system, or city infrastructure improvements.



# RMI Vision

---



RMI's vision is a world thriving, verdant, and secure, for all, for ever.



# Rocky Mountain Institute Innovation Center

Basalt, CO



Architect: ZGF Architects







White Steyer Impact Studio

Amory B. Lovins Atrium







Control Room

Whiteboard content:

1. Concept	2. Design	3. Implementation	4. Evaluation
...	...	...	...
...	...	...	...
...	...	...	...
...	...	...	...

Chalkboard content:


...

Whiteboard content:

- ...
- ...
- ...

# Climate

Temperature and Humidity Plot, Aspen, CO



The background image shows a panoramic view of a mountainous region during autumn. In the foreground, there are dense evergreen trees. The middle ground features a town with buildings and a river. The background consists of large, dark mountains under a blue sky with scattered white clouds. A white rectangular box is centered over the image, containing the text 'Thermal Comfort' in a black, sans-serif font, with a horizontal black line below it.

# Thermal Comfort

---

# Thermal Comfort in the News

## The New York Times

### Chilly at Work? Office Formula Was Devised for Men

By PAM BELLUCK AUG. 3, 2015



Molly Mahannah wears a sweatshirt and blanket at work in Omaha, wrapping herself up "like a burrito."  
Chris Mathian for The New York Times

## ScienceNews

MAGAZINE OF THE SOCIETY FOR SCIENCE & THE PUBLIC

### Building standards aren't to blame for chilly offices

By BETHANY BROOKSHIRE 4:30PM AUGUST 11, 2015



A recent study calculated women's resting metabolic rate and preferred office temperatures. But to figure out why women tend to be cold in the office, look not to science but to the person who controls the thermostat.



### Women, There's A Reason Why You're Shivering In The Office

AUGUST 04, 2015 12:13 PM ET

By RAE ELLEN BICHELL



It may be August, but in the office it feels like January. And there's a mysterious man to blame.  
Illustration: David Greig

SHARE







A diagram on a red background consisting of two white circles connected by a dotted white line. The larger circle on the left contains the text 'Human Comfort', and the smaller circle on the right contains the text 'Air Temp'.

Human  
Comfort

Air  
Temp



$$PMV = [0.303e^{-0.036M} + 0.028]\{(M - W) - 3.96E^{-8}f_{cl}[(t_{cl} + 273)^4 - (t_r + 273)^4] \\ - f_{cl}h_c(t_{cl} - t_a) - 3.05[5.73 - 0.007(M - W) - p_a] - 0.42[(M - W) \\ - 58.15] - 0.0173M(5.87 - p_a) - 0.0014M(34 - t_a)\}$$

# ASHRAE Scale of Thermal Sensation

---

3	HOT
2	WARM
1	SLIGHTLY WARM
0	NEUTRAL
-1	SLIGHTLY COOL
-2	COOL
-3	COLD


# Thermal Comfort Theory



# Room Data Sheet

## 2<sup>nd</sup> Floor Open Office (as designed)

Room Floor Plan



Internal Load Assumptions:

People	10
Equipment (Installed)	0.88 W/SF
Equipment (Operational)	0.37 W/SF
Lighting (Installed)	0.55 W/SF
Lighting (Operational)	0.40 W/SF
Daylighting	Auto Dimmers
Installed Heating	3.3 kW
Heating Setpoint	64 °F
Weather File	Aspen, CO Custom TMY10, 2004-2013

Comfort Design Parameters


Heating		Cooling	
Clo (max): (Trousers, sweater, T-shirt)	1.01	Clo (min): (Trousers, short sleeves)	0.57
Met (min): (Sitting, relaxed)	1.0	Met (max): (Standing, relaxed)	1.2
Air Speed:	19 FPM	Air Speed (max):	50 FPM

Schedule Description

Occupied weekdays 8:00am to 5:00pm.  
Equipment tracks occupancy, turning down to 7% load when unoccupied. Lighting is on with automatic daylight dimming when occupied, off when unoccupied.

# As Designed

## Room Thermal Comfort Performance



1. Upper boundary is based on the Elevated Air Speed Model, ASHRAE Standard 55-2013 Appendix G
2. Lower boundary is based on implementation of the CBE Personal Comfort System

# CBE Thermal Comfort Tool

**Select method:**

Air temperature:  °F

Mean radiant temperature:  °F

Air speed:  fpm

Humidity:  %


Metabolic rate:  met

Clothing level:  clo

✓ Complies with ASHRAE Standard 55-2010

PMV	0.08
PPD	5%
Sensation	Neutral
SET	77.4°F

$t_{db}$	32.0 °F
$rh$	0.0 %
$W_a$	0.0 lb <sub>w</sub> /klb <sub>da</sub>
$t_{wb}$	32.0 °F
$t_{dp}$	32.0 °F
$h$	0.0 btu/lb





# Controlling Peak Loads

---




# Earliest Modeling

---


Simplified model to examine:

- Energy Use
- Peak Loads
- Comfort




# Heating

**Code Building**  
30% Glazing - No Perimeter Heating



# Heating

**Heating Alternate**  
50% ASHRAE DG, R-40 Wall - No Perimeter Heating




# Heating

---

## Heating Comfort Optimized Alternate


All In (R-8 Window) - No Perimeter Heating



# Cooling

## Baseline


30% Glazing, Overhang (x1), 1.5" Concrete, PCM



# Cooling


## Cooling Alternate


50% Glazing, Overhang (x2), 6" Concrete, PCM




# Cooling


**Cooling Comfort Optimized Alternate**  
50% Glazing, Overhang (x2), 3" Concrete, 3" Concrete, 62F Min













# Personal Comfort - Hyperchair



# Personal Comfort

---




# Capture the Heat

---




# Expected Energy Use



# Breakdown of Plug Loads


---

June 2016 (kWh)



# Results: Actual Performance


Actual EUI is 15.9 kbtu/ft<sup>2</sup>/yr, lower than modelled EUI of 17.2 kbtu/ft<sup>2</sup>/yr





# Key Findings – Occupant Surveys

## CBE Post Occupancy Survey Results





# DC Power and Storage

---

RMI, Georgia Tech, and Confidential Project

# What Happened?

---




# Direct Current

---




# Plug Load Losses

---




# Ahead of Our Time?

---



"I THINK YOU SHOULD BE MORE EXPLICIT HERE IN STEP TWO."

# DC Distribution



# USB - C

---





# RMI Battery System

---

## Current Requirements:


- Peak shaving
- Test demand response scenarios, including rate structures

## Future Requirements:

- Islanding
- Integration with bi-directional electric vehicles
- DC distribution




# Installed!



# Battery Performance

---

- Goal was to keep peak demand below 50kW to avoid peak demand charges
- Most of the time below 10 kW
- Performance tests held under 10kw “demand peak”




# Demand Charge Avoidance – Geli Study moving RMI to California

## LOS ANGELES

SOUTHERN CALIFORNIA EDISON

Original Tariff: GS-2B

New Tariff: GS-1A




## SAN DIEGO

SAN DIEGO GAS & ELECTRIC

Original Tariff: ALTOU


New Tariff: TOU-A



# Traditional PV/Storage - RMI

---


## Separate Inverters




# Shared DC Bus PV/Storage – Georgia Tech

---

## Shared Inverter




# Shared DC Bus PV/Storage – Confidential Project



# Shared DC Bus PV/Storage – Confidential Project


---






# Shared DC Bus PV/Storage – Confidential Project

---




# Shared DC Bus PV/Storage – Confidential Project

---



# Shared DC Bus PV/Storage – Confidential Project

---





# THE NET ZERO CHALLENGE

	SINGLE FAMILY NEW	RETRO-FIT	MULTI-FAMILY	LOW RISE OFFICE	MID & HIGH RISE OFFICE	EDUCATIONAL	INSTITUTIONAL
HOT HUMID		<b>Willowbrook</b> 		<b>PNC BANK</b> 		<b>HPA</b> 	<b>AS-EPA</b> 
MIXED HUMID	<b>Zero Energy House</b> 					<b>Tyson</b> 	<b>Brock</b> <b>Chrisney</b> 
HOT DRY				<b>DPR Phoenix</b> 			
MIXED DRY				<b>Integral Office</b> 			
MARINE	<b>Eco-Sense Residence</b> 	<b>Zero Cottage</b> 	<b>zHome</b> 	<b>Painter's Hall</b> 	<b>Bullitt Center</b> 	<b>Bertschi School</b> 	<b>Packard Foundation HQ</b> 
COLD		<b>Mission Zero</b> 		<b>Omega Institute</b> 		<b>Hood River Middle School</b> 	<b>Phipps</b> 
VERY COLD				<b>RMI</b> 			

# Creating a better environment

---



Paul Schwer PE, LEED AP  
[paul.schwer@pae-engineers.com](mailto:paul.schwer@pae-engineers.com)

- By the numbers

DESIGN TARGET	UNITS	EXISTING (U.S.)	BETTER	BEST PRACTICE	RMI DESIGN
Delivered energy intensity	kBTU/sf-y	90	40-60	<30	17.2
Lighting power density: connected load	W/sf	1.5	0.8	0.4-0.6	0.49
Lighting power density: as-used net of controls	W/sf	1.5	0.6	0.1-0.3	0.27
Installed computers/appliances/tasklighting	W/sf	4-6	1-2	<0.5	0.88
Glazing R-value (center of glass)	sf-F°-h/BTU	1-2	6-10	≥20	12
Window R-value (including frame)	sf-F°-h/BTU	1	3	7-8	6.5
Glazing spectral selectivity*	$k_e = T_{vis}/SC$	1.0	1.2	>2.0	1.5-2.3
Roof solar absorptance and infrared emittance	$\alpha, \epsilon$	0.8, 0.2	0.4, 0.4	0.08, 0.97	N/A, PV Covers Roof
Whole-building airtightness	cfm/sf @ 0.3" w.g.	1.0	0.4	<0.25	0.20
Installed mechanical cooling	sf/ton	250-350	500-600	1,200-1,400+	None
Cooling design-hour efficiency**	kW/ton	1.9	1.2-1.5	<0.6	0.00
Level of installed perimeter heating	-	extensive	minimal	none	minimal
*A measure of how well the glazing lets in light without heat					
**Whole system, including pumps, fans, and cooling towers as well as chillers					
ADDITIONAL DESIGN TARGET ITEMS					
Wall R-value	sf-F°-h/BTU				R-50
Roof R-value	sf-F°-h/BTU				R-67 <sup>1</sup>
Window to wall ratio	%				26%
Heat recovery effectiveness	%				90% (Winter)
Installed mechanical heating	BTU/h-sf				7.5 BTU/h-sf

1. Individual roof sections vary between R-40 and R-80 for different shapes and constructions. This value represents an area-weighted average.

This table (except for the "Additional Target Items") is from a Book entitled "Re-inventing Fire: Bold Business Solutions for the New Energy Era" by Amory Lovins (2011). It is Table 3- "Benchmarking a New U.S. Office Building" (p. 108). These targets were developed by the Rocky Mountain Institute and are typical of a new midsize -to-large Class A office in an average US climate like the Mid-Atlantic states.